

## Short Form Test Report No. 16384F

- 1 - Test report reference and date  
**16384C** written in English: 26-02-2014
- 2 - Sponsor of the report : **Robin Resources (Malaysia) Sdn. Bhd.**  
**No. 1, Jalan Industri 5**  
**Taman Perindustrian Temerloh**  
**28400 Mentakab**  
**Pahang Darul Makmur, Malaysia**
- 3 - Testing lab: Warringtonfiregent (WFRGENT nv)
- 4 - Standard:  
For testing: BS 476-7 (1997)
- 5 - Tested product: **Robin FR1 MDF**  
**9 mm – 785 kg / m<sup>3</sup>**
- 6 - Results:  $V_m 1'30'' = V_m 10' = V_i 1'30'' = V_i 10' = 50 \text{ mm}$
- 7 - Classification: **Class 1**

SIGNED

APPROVED

*This short form classification report has been drafted according to EGOLF regulation R4 "Application note: clause 5.10 [5.10/1] – Issue 01-2002-06-21 – Types of test reports used in fire testing". Whilst the test data and classification provided within this short report was obtained in a test conducted fully in accordance with the standards BS 476-7 (1997), the presentation of the results in this short form may not satisfy the requirements of that standard and EN ISO/IEC 17025: 2005/AC: 2006. The presentation of the results in this manner is made by agreement with the sponsor and use of the information herein for product assessment, approval or certification purposes will be restricted. The full report No. 16384C is available at Robin Resources (Malaysia) Sdn. Bhd..*

This document is the original version of this document and is written in English. This document may be used only literally and completely for publications. - For publications of certain texts, in which this document is mentioned, our permission must be obtained in advance.  
The authenticity of the electronic signatures is assured by Belgium Root CA.